



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/17/09

Code 50.11.5.1-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title <b>Indiana Residential Code</b>		Edition <b>2009</b>
Section number and title <b>703.8 Flashing</b>		Page <b>1</b>
Proponent <b>SW Indiana Builders and Building Officials</b>	Title	
Address <b>2175 N Cullen Ave; Evansville, IN 47715</b>		Phone <b>812-479-6026</b>
<b>Center Complex; Room 310; Evansville, IN 47708</b>		<b>812-436-7868</b>
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution PROPOSED CODE CHANGE (Check One)		
<b>Add exception to read as follows: "Windows indicated by the manufacturer as self-flashing, having a continuous lap of not less than 1.125 inches (28 mm) over the sheathing material or building paper around the entire permimeter of the opening, including corners, do not require additional flashing."</b>		
REASON		
<b>This amendment would bring forth an existing standard for self-flashed windows.</b>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		